




COMPLIANCE TESTED by berkeley analytical

VOC Emission Test Certificate

Product Name: Dex-O-Tex - Decor - Flor Resin

Product Sample Information		Certificate Information	
Company:	Crossfield Products Corp.	Certificate No:	201022-07
Company Website:	www.crossfieldproducts.com	Certified By:	
Product Type:	Floor Coatings or Adhesives		Raja S. Tannous, Laboratory Director
Date Produced:	9/28/2020	Date:	October 22, 2020

Reference Standard: California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario ¹	Individual VOCs of Concern ²		Formaldehyde ³		TVOC ⁴
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤ 0.5 mg/m ³
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤ 0.5 mg/m ³

Product Coverage⁵: 12 mils; See attached letter

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 – 4.9 mg/m³, and ≥5.0 mg/m³
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard
- ANSI/GBI 01, Green Building Assessment Protocol

Narrative: Crossfield Products Corp. selected a sample representative of its Dex-O-Tex - Decor - Flor Resin epoxy coating product and submitted it on 10/1/2020 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 853-011-03A-Oct2220.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

DEX-O-TEX[®]

Scientifically Superior[™] Technologies

Dex-O-Tex Product Line
by Crossfield Products Corp.

www.dexotex.com

West Coast Office
3000 E. Harcourt Street
Rancho Dominguez, CA 90221
Tel 310-886-9100
Fax 310-886-9119

East Coast Office
140 Valley Road
Roselle Park, NJ 07204
Tel 908-245-2800
Fax 908-245-0659

Performance Proven Since 1938

Manufacturers of:

*Decorative and Functional
Commercial, Industrial and Institutional
Floors and Wall Coating Systems*

*Chemical, Slip and Temperature
Resistant Floor and Coating Systems*

*Electro-Static Dissipative and
Conductive Flooring Systems*

*Underlayments, Waterproofing
Membranes and Repair Systems*

Promenade Roof Decking

*Parking Deck Surfacing
and Sport Surfacing Systems*

*Moisture Vapor Transmission
Mitigation Systems*

Marine Deck Coverings

September 30, 2020

Alec Huang
Berkeley Analytical
Via email

Subject: Decor-Flor Resin

RE: Sample for CDPH 01350 Testing

Dear Alec ;

The construction of the sample submitted for test is as follows:

- 1.) Lightly abrade the substrate
- 2.) Solvent wipe and allow to evaporate completely.
- 3.) Apply 12 mils Décor-Flor Resin #0460/#0461

Samples were made September 28, 2020 and shipped via Fed -Ex
September 30, 2020, the tracking number is 771674967792 due for delivery by
10:30 AM October 1, 2020.

If you have any questions, please don't hesitate to call.

Sincerely,
Crossfield Products Corp.



Steven Schroeder
Vice President



Winner of the Export
Achievement Award,
Presented by the President
of the United States

LEED[®] GREEN BUILDING CREDITS



*Dex-O-Tex thin-set epoxy
terrazzo & other systems can
be used with approved state-
of-the-art recycled glass filler
& glass chips, which can
contribute to LEED[®] Green
Building credits*